

# Design and Implementation of Power Theft Detection and Monitoring using wireless Technology

Trupti A.Bhosale  
truptibhosale09@gmail.com

Prof.B.G.Hogade  
bghogade@gmail.com

Department Of Electronics Engineering, University of Mumbai  
Terna Engineering College, Nerul(W), Navi Mumbai

## ABSTRACT

Electricity losses during transmission and distribution are extremely high in India. One of the reason for this the presence of non-technical energy losses (NTL) that is energy losses caused due to theft, meter malfunction etc. Wireless network based architecture is proposed in this paper for monitoring optimizing the electric transmission & distribution system in India. The system consists of two area consumer side & supplier side. The proposed module incorporates electricity measuring & information transmission footmarks. This design incorporates effective solution for power theft & save large amount of electricity & thereby electricity will be available for more no. of consumers than earlier in a highly populated country such as India.

**Keywords-** Power Theft Detection System, GSM/GPRS Technology.

## I. INTRODUCTION

Electricity is vital for our everyday life & a backbone for the industry. While technology is on the raising slopes, we should also note the increasing immoral activities. With a technical view power theft is a non-ignorable crime that is highly prevented & at the same time it directly affected the economy of a nation. Power consumption & losses have to be closely monitored so that the generated power is utilized in a most efficient manner. The system prevents the illegal usage of electricity. There are four main ways that electricity can be accessed illegally. Electricity can be fraudulently accessed through illegal hook-ups Fig.1, meter tampering or bypass, billing irregularities & unpaid bills. Illegal hook-ups occur when electrical wires are directly connected to the grid system from the individual's premises. Meter tampering can be done by inserting a reading on the meter. Billing irregularities is a manifestation of corruption in the utility company through bribes to utility officials.



**Figure1:** Tapping electricity directly from the distribution feeder -bypassing the meter.

## II. BACKGROUND OVERVIEW

A number of attempts have been made to minimize electricity theft problem.

**Financial Rewards:-**Utility companies encourage consumers to report electricity theft, sometimes offering big reward for information leading to conviction of anyone stealing electricity. Unfortunately, most cases are never identified in both domestic and industrial setup due to lack of timely information.

**Periodic Checks:-**Electricity theft frequently takes place after service has been disconnected. Some utility companies periodically checks disconnected meters if customers has not contacted them to reconnect services. This labour- intensive, manual process has little chance of success given that the apartment averages 70% turnover of tenants annually.

**Meter Readers:-**Utility meter readers typically suspect that electricity theft is taking place when they find a broken meter tag or other signs of tempering. But as more utility companies outsource the meter reading function to third parties, training meter readers to detect theft is becoming more difficult and less efficient. In addition third party meter readers do not read disconnected meters.

In wireless **AMR System** using zigbee technology used to telemeter the consumption of electricity, gas, water, etc. Since the direct physical access or visual reading of meters are very inconvenient using zigbee. But its range is limited & it used only for meter reading purpose but it could not find out where the power theft has occurred.

In a **NOVEL Technique** for preventing current method electricity stealing, the technique improved current coupling device of electric power measuring equipment & added two high frequency coupling winding in it. Through detection of high frequency sine signal, the actual state of CT can be real timely & correctly monitored. However the frequency of detection signal can't be over high. The higher the frequency is, the more expensive the signal generation and filter cost is, and the larger the impedance of CT secondary side is. When the frequency of the signal is too high, the impedance under normal and open circuit states both approach infinite, which is difficult to distinguish between each other.


### III. THE PROPOSED ARCHITECTURE

The whole proposed system architecture based on GSM/GPRS network. The architecture consist of two areas namely consumer side and supplier side. The proposed system architecture shown in Figure 3. It consist of power supply, GSM/GPRS Modem, Microcontroller (LPC2141/48), current tester WCS2702 & LCD display etc.

#### A. **Microcontroller:**

The LPC214148 microcontrollers are based on a 16-bit ARM7TDMI-S CPU with real-time emulation and

embedded trace support, which combine microcontroller with embedded high speed flash memory ranging from 32 kb to 512 kb. A 128-bit wide memory interface and unique accelerator architecture enable 32-bit code execution at the maximum clock rate.




**Figure2:** LPC2141/48 Microcontroller

For critical code size applications, the alternative 16-bit Thumb mode reduces code by more than 30 % with minimal performance penalty.

Due to their tiny size and low power consumption, LPC2141/48 are ideal for applications where miniaturization is a key requirement, such as access control and point-of-sale. Serial communications interfaces ranging from a USB 2.0 Full-speed device, multiple UARTs, SPI, SSP to I2C-bus and on-chip SRAM of 8 kb up to 40 kb, make these devices very well suited for communication gateways and protocol converters, soft modems, voice recognition and low end imaging, providing both large buffer size and high processing power. Various 32-bit timers, single or dual 10-bit ADC(s), 10-bit DAC, PWM channels and 45 fast GPIO lines with up to nine edge or level sensitive external interrupt pins make

these microcontrollers suitable for industrial control and medical systems [3].

**PC/VB.NET/SQL (DEPARTMENT SERVER)**



## 230 VAC

**Figure3:** Block Diagram of Proposed System

The ARM7TDMI-S processor is a member of the ARM family of general purpose 32-bit microprocessors. The ARM family offers high performance for very low -power consumption and gate count. The ARM7TDMI-S Processor also employs a unique architectural strategy known as Thumb, which makes it ideally suited to the high volume applications with memory restrictions, or applications where code density is an issue.

The key idea behind thumb is that of a super-reduction instruction set. Essentially, the ARM7TDMI-S processor has two instruction sets:

- The standard 32-bit ARM set
- A 16-bit Thumb set

The Thumb set's 16-bit instruction length allows it to approach twice the density of standard ARM code while retaining most of the ARM's performance advantage over a traditional 16-bit processor using 16-bit registers. This is possible because Thumb code operates on the same 32-bit register set as ARM code.

The ARM architecture is based on Reduced Instruction Set Computer (RISC) principals. The RISC instruction set, and related decode mechanism are much simpler than those of Complex Instruction Set Computer (CISC) designs. This simplicity gives:

- a high instruction throughput
- an excellent real interrupt response
- a small, cost-effective macrocell.

### B. *Current Tester:*



**Figure4:** WCS2702 Current Sensor

The Winson WCS2702 provides economical and precise solution for both DC and AC current sensing in industrial, commercial and communications systems.

The WCS2702 consists of a precise, low-temperature drift linear hall sensor IC with temperature compensation circuit and a current transformer with 110 m $\Omega$  typical internal conductor resistance. This extremely low resistance can effectively reduce power loss, operating temperature and increase the reliability greatly. Applied current flowing through this conduction path generates a magnetic field which is sensed by the integrated Hall IC and converted into a proportional voltage [4].

The terminals of the conductive path are electrically isolated from the sensor leads. This allows the WCS2702 current sensor to be used in applications requiring electrical isolation without the use of opto-isolators or other costly isolation techniques and make system more competitive in cost.

### C. *GSM Modem:*



**Figure5: GSM/GPRS MODEM**

GSM/GPRS TTL -Modem from rhydoLABZ is built with SIMCOM Make SIM900 Quad-band GSM/GPRS engine, works on frequencies 850 MHz, 900 MHz, 1800 MHz and 1900 MHz It is very compact in size and easy to use as plug in GSM Modem. The Modem is designed with 3V3/5V TTL interfacing circuitry, which allows you to directly interface to 5V microcontrollers ( PIC, Arduino, AVR etc) as well as 3V3 Microcontrollers (ARM,ARM Cortex XX, etc). The baud rate can be configurable from 9600-115200 through AT command. Initially Modem is in Auto baud mode. This GSM/GPRS TTL

Modem is having internal TCP/IP stack to enable you to connect with internet via GPRS. It is suitable for SMS as well as DATA transfer application in M2M interface. The modem needed only two wires (Tx, Rx) except Power supply to interface with microcontroller/Host. The built in Low Dropout Linear voltage regulator allows you to connect wide range of unregulated power supply (4.2V -13V). Yes, 5 V is in between. Using this modem, you will be able to send & Read SMS,



connect to internet via GPRS through simple AT commands [5].

#### D. LCD:

#### **Figure6: 2x16 Serial LCD Display Module**

Liquid crystal Display (LCD) displays temperature of the measured element, which is calculated by the microcontroller. CMOS technology makes the device ideal for application in hand held, portable and other battery instruction with low power consumption.

As the output of our circuit should be displayed in some form or the other, so we have selected LCD display as it can display 16 characters at a time. It is also easy to interface with the microcontroller without any decoder. So it is better than the seven segment display.

### IV IMPLEMENTATION PLATFORM

Keil Software: Used for Embedded system

VB.NET for PC side coding

SQL server for database

Eagle software for PCB designing

### V ALGORITHM

#### *Area side:*

- 1 Start.
- 2 Initialize Beep verification.
- 3 Serial port initialization.
- 4 ADC port initialization.
- 5 LCD verification.
- 6 SIM Modem initialization.
- 7 SIM GPRS initialization to open GPRS context.
- 8 Monitor the incoming voltage from current IC.
- 9 Calculate consumption Wattage or Power.
- 10 Create a HTTP POST packet.
- 11 Send this packet to the web server on internet.
- 12 Repeat above steps 6 to 9.

#### *Department side:*

- 1 Start.
- 2 System initialization.
- 3 Beep verification.
- 4 Serial port initialization.
- 5 ADC port initialization.
- 6 LCD verification.
- 7 Monitor the incoming packet from net (Web server).
- 8 Monitor the incoming voltage/wattage from the hardware/current sensor.
- 9 Compare both.
- 10 If difference > limit, then generate alert & record the log.
- 11 Repeat above steps 6 to 9.

This proposed approach aims at solving major problem faced by the existing electric supply system, such as wastage of energy, power theft. This paper is aimed at reducing the heavy power and revenue losses that occur due to power theft by the customers. The ability of proposed system is to inform or send data digitally to a remote station using GSM/GPRS technique.

## VI FEATURES

- The proposed system provides the solution for some of the main problems faced by the existing electricity supply system, such as wastage of energy, power theft, manual billing system, and transmission line fault.
- We can detect the location from where the power is being stolen which was not possible before.
- Real time theft capturing.
- Currently used energy meters can be modified into this sensor, so no need to replace currently used energy meters.

## I RESULT:

- Power theft can be calculated by using the following formula:  
Difference= Electricity Supply- Electricity Consumed
- Where, Electricity Consume is stored at sever database transmitted by consumer meter and Electricity supply measured at Department side. If difference is negligible then there is no power theft otherwise there is a power theft.

## II CONCLUSION:

## III REFERENCES:

- [1] A. R. Devidas, M. V. Ramesh, "Wireless Smart Grid Design for Monitoring and Optimizing Electric Transmission in India," IEEE 2010 Fourth International Conference on Sensor Technologies and application.
- [2] "National Electricity Policy," The Gazette of India, EXTRAORDINARY PART I - Section 1, Ministry of Power, New Delhi, Dated the 12th, February, 2005, RESOLUTION No. 23/40/2004-R&R (Vol.II)

- [3] Koninklijke Philips Electronics N.V. 2005 Date of release:  
7 September 2005 Document number: 9397 750 14985  
Published in the Netherlands.
- [4] Winson semiconductor corporation, [www.winson.com.tw](http://www.winson.com.tw)
- [5] [rhydolabz.com](http://rhydolabz.com)
- [6] [www.sim.com/wn](http://www.sim.com/wn)
- [7] Electrical Power Supply System for India,”  
[www.wikipedia.org](http://www.wikipedia.org), February 2010.
- [8] *Smart Grid*, [www.wikipedia.org](http://www.wikipedia.org)
- [9] Zhang Cheng, Ge Jianhua, Yu Hui, Zhang Xianlin “ET  
Gravimeter Data Collecting System Based on GPRS” The  
Eighth International Conference on Electronic  
Measurement and Instruments 2007
- [10] Gujing Han , Weiping Luo “A Novel Technique for for  
Preventing Current Method Electricity-stealing”, IEEE  
2010 978-1-4244-4813-5/10